

CE



UYGUNLUK ONAYI ATTESTATION OF COMPLIANCE

Reference No:	TRCN-20057ZBE01		
Applicant:	ZHEJIANG BENYI ELECTRICAL CO., LTD. Wenzhou Bridge Industrial Zone, Beibaixiang, Yueqing, Zhejiang 325603, China		
Manufacturer:	ZHEJIANG BENYI ELECTRICAL CO., LTD. Wenzhou Bridge Industrial Zone, Beibaixiang, Yueqing, Zhejiang 325603, China		
Brandname:	ZJBENY		
Product:	DC Circuit Breaker		
Type/Model:	BDM-125 In:125A, 100A, 80A, 65A, Ue:DC500V;Umip:8kV;Ui:DC500V;li=5In;lcs=lcu=15kA;IP66;Cat A;40°C BDM-250 In:125A, 160A, 200A, 225A, 250A, Ue:DC500V;Umip:8kV;Ui:DC500V;li=5In;lcs=lcu=15kA;IP66;Cat A;40°C		
Reference Directive(s):	Low Voltage Directive (LVD) 2014/35/EU		
Reference Standard(s):	EN 60947-2:2017		
Base of attestation:	File of Technical Documentation, Test Report No. A170533/1, A170533/2		
Issue Date:	26.02.2020	Expiry Date:	25.02.2025

Integra96, hereby confirms, that the presented file of technical documentation declares conformity of the above mentioned product(s) with the technical requirements of Parliament and Council Directive 2014/35/EU (Low Voltage). This attestation has been issued as per company required. This attestation does not abrogate the compulsory obligation of the manufacturer to issue the declaration of conformity.


Ergün CENGİZ
İNTEGRA96 Belgeleendirme
İZMİR, (rev. 00) <26.02.2020

